

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7610-1552:100

Page 1 of 1

CATEGORY: Automatic Extinguishing Systems (Misc. Accessories)

LISTEE: CECA, LLC, 1920 N. Redmond Rd., Jacksonville, AR 72076
Contact: Edward Nance (501) 982-9463 Fax (501) 982-9676*

DESIGN: Models C-100 and C-100-WCN adjustable steel drop nipples. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rate working pressure, direction of flow, maximum sprinkler temperature rating and UL label.

APPROVAL: Listed as adjustable steel drop nipples for use with ordinary, intermediate and high temperature pendent and horizontal sidewall sprinklers in systems having a pressure rating maximum of 175 psi.

NOTE: Formerly 7610-1248:100

*Rev. 07-03-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 3, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager